

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman
FROM: Kenneth Schermerhorn, Asst. Fire Inspector
SUBJECT: PB-07-29
Silver Stream Properties, LLC
SBL: 3-1-35
DATE: March 10, 2008

Fire Prevention Reference Number: FPS-08-013

A review of the above referenced plan has been conducted and is unacceptable for the following reasons:

- 1) Fire Dept. Connection locations to be determined.**
- 2) Hydrants needed**